

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	19 - Revelstoke
School Name:	Arrow Heights Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-19
	Date of next inspection: 2024-12-19
	Date and type of most recent maintenance: September 19 th filter change on all air handler units
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 20%
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Schedule runs from 7:00am- 10:00pm
Other Relevant Information:	Inspect filters every three months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	93 - Conseil scolaire francophone
School Name:	Arrow Heights Elementary (Portables)
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-19
	Date of next inspection: 2024-12-19
	Date and type of most recent maintenance: September 19 th filter change on all furnace units
RECOMMENDATION: Increase supply of outside air	Yes/No: No
	Detail: N/A
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Schedule runs from 7:00am- 10:00pm
Other Relevant Information:	Inspect filters every three months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	19 - Revelstoke
School Name:	Begbie View Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-18
	Date of next inspection: 2024-12-18
	Date and type of most recent maintenance: September 18 th filter change on all air handler units
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 20%
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Schedule runs from 7:00am- 10:00pm
Other Relevant Information:	Inspect filters every three months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	19 - Revelstoke
School Name:	Columbia Park Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-18
	Date of next inspection: 2024-12-18
	Date and type of most recent maintenance: September 18 th filter change on all roof top units
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 20%
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Schedule runs from 7:00am- 10:00pm
Other Relevant Information:	Inspect filters every three months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	19 - Revelstoke
School Name:	Revelstoke Secondary School
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2024-09-19
	Date of next inspection: 2024-12-19
	Date and type of most recent maintenance: September 19 th filter change on all air handler units
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 20%
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Schedule runs from 7:00am- 10:00pm
Other Relevant Information:	Inspect filters every three months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca