

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	93 - Conseil scolaire francophone
School Name:	Ecole Des Glaciers P1- P5
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-10-01
	Date of next inspection: 2021-12-01
	Date and type of most recent maintenance: October 1st filter change on all portables.
RECOMMENDATION: Increase supply of outside air	Yes/No: No
	Detail: N/A
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade): Filters vary from MERV-8 to MERV-11 (MERV-13 not available)
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: All thermostats have been programmed from 7:00- 5:00
Other Relevant Information:	Replacement filters ordered 2021-10-01 Inspect filters every two months (minimum)
District Contact for any Questions:	Name: Andrew McDade
	Phone Number: (250) 814- 7914
	Email: amcdade@sd19.bc.ca